

GSTIN : 08AVKPK0126G1ZT

Mob. : 9602028585

VIDHADHAR FIRE SAFETY SERVICES

(INSTALLATION OF ALL TYPE OF FIRE FIGHTING EQUIPMENTS)

Office : 2-A, Basant Vihar, Jhunjhunu (Raj.)

Inspection/Testing, Servicing and Refilling of all type of Fire Extinguishers. Expert in Fire load Assessment, fire safety audit, survey & Design of Hydrant, Sprinkler system etc.

Ref No.

Date : _____

Ref.No.VFSS/JJN/ 145/25-26

Dated – 09-01-2025

CERTIFICATE

This Is to certify that the firefighting equipment installed in the premises of PIRAMAL GIRLS SR.SEC.SCHOOL(CBSE),BAGAR Near Nagarpalaika, Bagar,Jhunjhunu have been completed installed fire extinguishers and these are perfect in use for operation in any fire emergency. All school staff members have been trained to use the fire equipments.

This certificate is valid from 09-01-2025 to 08-01-2026

Inspected & Issued by

For Vidhadhar Fire Safety Services

[Signature]
Proprietor

VIDHADHAR FIRE SAFETY SERVICES

Reg. Off. : 4B, Mohan Nagar, Sirsi Road, Jaipur (Raj.) Mob.: 9602028585

Branch Off. : 2-A, Basant Vihar, JHUNJHUNU (Raj.) Mob.: 9602028585

Inspection/Testing, Servicing and Refilling of all type of Fire Extinguishers. Expert in Fire load Assessment, fire safety audit, survey & Design of Hydrant, Sprinkler System etc.

Ref. No. 19/15, Piraman Vidya ER. Sec.

Date 08/01/25

School Bagan (534)
(CBSE English Medium)

INSPECTION REPORT

This is certify that we have carried-out the yearly inspection & checking the following fire extinguishers of-

We found that/ According to my serve

We furnish below the details of Inspection & checking.

S.No.	Particular	Type	Qty.	Cap.	Type of checking	Remark
1.	Extinguisher	DCP	-	-	Delivery hose Gun. Cartridge & Powder Cap, Locking etc.	
2.	Extinguisher	CO ₂	-	-		
3.	Extinguisher	ABC	08	4 kg	Delivery hose Gun. Cartridge & Powder Cap, Locking etc.	
4.	Bucket	Sand	01	5 kg		

Inspection On : 08/01/25

Next Due On : 07/01/26

Inspected & Issued By:

For : VIDHADHAR FIRE SAFETY SERVICE

(Authorized signatory)