

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE**

No. 52

Date : 21.4.2025

It is certified that an inspection team headed by Surendra Kumar Sharma  
Junior Chemist (Name of Officers with  
designation) from PHED Laboratory, Jharkhand (Name of  
Department/Office) Inspected the Piramal Girls Senior Secondary  
School, Near Nagarpalika, Bageshwar (Name & Address of the  
School) on 21.4.2025 and found that the Piramal Girls Senior  
Secondary School, Bageshwar (Name of school) has safe drinking water  
facilities for the students and members of staff of the institution and is maintaining the hygienic  
sanitation condition in the school building & the campus as per the norms prescribed by the  
Central/State/U.T Govt.

The above valid for a period of 1 year

Signature with Seal : (सुरेन्द्र कुमार शर्मा)  
कनिष्ठ रसायनज्ञ  
Name : जन स्वास्थ्य अभि० विभाग  
Designation : प्रयोगशाला, झुझुनू

To Piramal Girls Sen Sec. School  
Near Nagarpalika, Bageshwar

(Name & Address of the Institution)




BOARD OF MUNICIPALITY  
BAGAR, Jhunjhunu (Raj)

L.No. 136

Dated- 24/04/25

CERTIFICATE OF SANITATION

This is to certify that Piramal Girls Sr. Sec. School, (English Medium), Bagar, Run and managed by Dr. Mohanlal Piramal Charitable Trust, Bagar has maintained a clean and pollution free environment for the students. The institution has maintained a proper drainage system. It has sufficient number of toilets and urinals separate for boys, girls and staff. Toilets are regularly cleaned. The overall sanitation system of the school is good and satisfactory.

  
24.4.25  
अधिष्ठापनी अधिकारी  
नगरपालिका बगड़



PUBLIC HEALTH ENGINEERING DEPARTMENT  
LABORATORY JHUNJHUNU

CHEMICAL EXAMINATION REPORT OF WATER

No. Lab. / Chem. /2024-25/ S 2

Date - 21-4-2025

To,

The Principal

Piramal Girls Sr Secondary School

(English Medium) Bagar

Ref- Yours letter no. 106 dated 02-04-2025

District - Jhunjhunu

Tehsil:- Jhunjhunu

Date of Exam -21-04-2025

A	Name & Location of Source	IS-10500:2012		Water Sample Piramal Girls Sr Sec School (English Medium)
B	Village/ Town			Bagar
C	Date Of Collection			21-04-2025
D	Lab. Sample No.			C-06
Sr. No	Parameters	Desirable limits	Permissible limits	Value
1	pH	6.5—8.5	6.5—8.5	8.48
2	Turbidity[NTU]	1	5	Nil
3	Temperature[C]	-----	-----	25
4	Colour[Units]	5 Hazen Unit	15 Hazen Unit	None
5	Odour	Unobjectionable	Unobjectionable	Unobj.
6	Total Alkalinity[asCaCO <sub>3</sub> ]	200	600	40
7	Total Hardness[asCaCO <sub>3</sub> ]	200	600	16
8	Calcium [asCa]	75	200	4
9	Magnesium [as Mg]	30	100	1.46
10	Chloride[asCl <sup>-1</sup> ]	250	1000	24
11	Nitrate[as NO <sub>3</sub> <sup>-1</sup> ]	45	45	03
12	Fluoride [as F <sup>-1</sup> ]	1.0	1.5	0.20
13	TDS	500	2000	126

Note: All Results Except pH in mg/L.

(S K Sharma)

Junior Chemist

PHED Laboratory Jhunjhunu